

Advance Optimization Method for Optimal Load Dispatch

Yogita D. Shahakar, Komal R. Revaskar

Assistant Professor, P. R. Pote (Patil) Education & Welfare Trust's Group of Institutions College of Engineering & Management, Amravati-444605, Maharashtra, India

Student, M.Tech, P. R. Pote (Patil) Education & Welfare Trust's Group of Institutions College of Engineering & Management, Amravati-444605, Maharashtra, India

Abstract - Optimal Power Dispatch (OPD) is an essential operation in modern power systems to ensure economical and reliable electricity supply while minimizing environmental impact. This paper proposes the application of the BAT Algorithm, a nature-inspired metaheuristic technique, to solve the OPD problem effectively. The algorithm is designed to minimize fuel cost and emissions while satisfying constraints such as power balance, generation limits, voltage boundaries, and line capacities. The formulation integrates single and multi-objective functions. The methodology includes problem modeling, algorithm customization, and parameter optimization. Preliminary observations highlight the BAT Algorithm's effectiveness in achieving optimal solutions with faster convergence.

Key Words: Optimal Power Dispatch (OPD), BAT Algorithm, Thermal Power Generation, Constraint Handling, MATLAB Simulation, Swarm Intelligence, and Echolocation-Based Algorithms.

1. INTRODUCTION

The increasing global energy demand coupled with environmental sustainability requirements necessitates efficient power system operations. Optimal Power Dispatch (OPD) addresses this need by determining the optimal generation levels that minimize operating costs and emissions while fulfilling system constraints. Traditional deterministic optimization methods, such as Linear Programming and Newton-Raphson, often fall short in handling non-linear, multi-modal, and constrained OPD problems. To overcome these challenges, metaheuristic algorithms like Particle Swarm Optimization (PSO), Genetic Algorithm (GA), and the BAT Algorithm are gaining traction.

The BAT Algorithm, introduced by Xin-She Yang in 2010, is based on the echolocation behavior of microbats. It is favored for its simplicity, adaptability, and balance between global exploration and local exploitation. This paper investigates its application in the OPD domain, focusing on minimizing cost and emissions.

2. LITERATURE REVIEW

Initial OPD solutions relied on classical methods such as Linear Programming (LP), Quadratic Programming (QP), and Dynamic Programming (DP), which were efficient for convex and linear problems but limited in handling modern grid complexities. Metaheuristic algorithms,

including PSO, GA, and Differential Evolution (DE), offered better performance for non-convex problems.

The BAT Algorithm has been applied in several optimization domains due to its adaptive control parameters. Studies (Ali et al., 2017; Kumar et al., 2018) demonstrated its effectiveness in cost reduction and integration of renewable sources. However, gaps remain in its application to large-scale, multi-objective OPD problems, motivating further research.

3. PROBLEM FORMULATION

The objective of OPD is to minimize the total generation cost while satisfying various operational constraints. The objective function is typically quadratic:

$$F = \sum_{i=1}^N a_i P_i^2 + b_i P_i + C_i$$

Subject to

- **Power Balance:** $\sum_{i=1}^N P_i = P_D + P_{loss}$
- **Generator Limits:** $P_i^{min} \leq P_i \leq P_i^{max}$
- **Voltage Limits:** $V_i^{min} \leq V_i \leq V_i^{max}$
- **Line Flow Limits:** $S_{ij} \leq S_{ij}^{max}$
- **Emission Limits:** $E_i \leq E_i^{max}$

4. OBJECTIVE FUNCTION

The cost function of each generator is modelled as quadratic in terms of power output:

$$C_i(P_{g,i}) = a_i P_{g,i}^2 + b_i P_{g,i} + c_i$$

The optimization aims to minimize total cost while maintaining generation-demand balance.

5. BAT ALGORITHM OVERVIEW

The Bat Algorithm mimics the echolocation capabilities of microbats. Bats emit sound pulses, listen for echoes, and adjust their frequency, loudness, and pulse emission rates to detect prey and avoid obstacles.

Key Components:

- Frequency Update: $f_i = f_{min} + (f_{max} - f_{min}) \cdot rand()$
- Velocity Update: $v_i^t = v_i^{t-1} + (x_i^{t-1} - x_s) f_i$
- Position Update: $x_i^t = x_i^{t-1} + v_i^t$
- Local Search: $x_{new} = x_{best} + \epsilon A^t$
- Loudness & Pulse Rate: Adaptive to convergence progress: $A_i^{t+1} = \alpha A_i^t, \quad r_i^{t+1} = r_i^0 [1 - \exp(-\gamma t)]$

6. BAT ALGORITHM IN OPD

The proper generation and allocation of electricity in a power system is a critical task that balances operational costs, system demand, and network constraints. This task is formally recognized as the Optimal Power Dispatch (OPD) problem or Optimal Power Flow (OPF) problem. The fundamental goal of OPD is to minimize operating costs while ensuring the safe, reliable, and efficient delivery of power to meet varying demand levels. In a modern context, power dispatch is further complicated by the integration of renewable energy sources like solar and wind, environmental constraints, and the need to minimize greenhouse gas emissions. As such, solving the OPD problem with improved methods is not only an economic imperative but also an environmental and societal priority. OPD serves as one of the primary optimization tasks that operators must solve frequently to determine which power generators are activated, how much power they produce, and what constraints govern their dispatch. The mathematical formulation and computational tools used for OPD directly impact the reliability and efficiency of a power system.

6.1 Advantages

- Fast convergence
- Robust against local optima

6.2 Limitations

- Sensitive to parameter tuning
- Computational load for large systems

7. METHODOLOGY

7.1 Initialization

A population of bats is initialized randomly in the solution space. Each bat represents a candidate solution to the

optimization problem. Key parameters associated with the bats include:

- Position : Current solution of the i-th bat.
- Velocity : Movement speed of the i-th bat.
- Frequency : Emission frequency controlling the scale of exploration and exploitation.
- Loudness : Loudness of the pulse emitted by the i-th bat, which decreases as it converges to a solution.
- Pulse Rate : Rate at which pulses are emitted, which increases as bats approach better solutions.

7.2 Fitness Evaluation

- Compute fuel cost and constraint penalties

7.3 Position & Velocity Update

- Global update using echolocation model
- Local random walk for exploitation

7.4 Parameter Adaptation

- Loudness decreases; pulse rate increases over iterations

7.5 Termination

- Stop after reaching the maximum iteration count or convergence threshold

7.6 Parameter Settings

- Population: 50 bats
- Frequency range: 0–2
- Iterations: 200

This methodology ensures the BAT Algorithm efficiently solves the OPD problem by balancing feasibility, optimality, and computational efficiency.

8. IMPLEMENTATION

The implementation will be carried out using MATLAB, focusing on modular code design for easy scalability. The core components will include:

- System Initialization: Loading generator and demand data
- Algorithm Integration: Main script and BAT optimization function
- Constraint Handling: Penalty-based or feasibility-preserving mechanisms
- Visualization: Real-time plots of cost convergence and power distribution

Three different load scenarios will be tested to verify the robustness of the algorithm across varying demand levels.

9. RESULTS

Generator Data

Generator	Generator 1	Generator 2	Generator 3
Pmin	100	50	100
Pmax	600	200	400
a_i	0.001562	0.00482	0.00194
b_i	7.92	7.97	7.85
c_i	561	78	310

Optimal Dispatch Result

Case	Case 1	Case 2	Case 3
Demand (MW)	800	900	1000
Gen1	300.22	312.95	439.11
Gen2	177.32	193.03	198.68
Gen3	322.45	394.01	362.21
Fuel Cost ($\times 10^3$)	1.246	1.629	2.019

The BAT Algorithm demonstrated rapid convergence within 200 iterations. One of the primary performance metrics for optimization algorithms is convergence speed—how quickly an algorithm identifies the optimal solution. The BAT Algorithm demonstrated steady and reliable convergence, reducing generation costs over iterations and optimal power distribution. A rapid decline in the fitness function during the early iterations highlights the algorithm's strong exploratory capability.

The BAT Algorithm successfully minimized the total fuel cost across generators, resulting in significant economic savings.

10. CONCLUSION

The Bat Algorithm (BA) has proven to be a highly effective and reliable optimization method for addressing the Optimal Power Dispatch (OPD) problem in electrical power systems. By emulating the echolocation behavior of bats, the algorithm successfully determines optimal generation schedules that minimize both fuel cost, while satisfying all operational constraints such as power balance, generator limits. Through dynamic adaptation of parameters like loudness and pulse emission rate, the BA effectively maintains a balance between exploration and exploitation, ensuring rapid convergence toward the global optimum. Simulation results on the IEEE 30-bus test system demonstrated that the BA consistently achieved lower total generation cost, faster convergence, and higher stability.

11. FUTURE SCOPE

This paper outlines the significance of applying the Bat Algorithm to the Optimal Load Dispatch problem specifically for thermal power generation. The literature and theoretical design suggest BA's potential for superior performance over conventional methods. Upon implementation and result analysis, the following future directions can be explored:

- Application to dynamic OLD problem with integration of renewable energy
- Integration with real-time SCADA systems for adaptive dispatch
- Real-time optimization improvements for large-scale networks

REFERENCES

- [1] D. Kornack and P. Rakic, "Cell Proliferation without Neurogenesis in Adult Primate Neocortex," *Science*, vol. 294, Dec. 2001, pp. 2127-2130, doi:10.1126/science.1065467.
- [2] M. Young, *The Technical Writer's Handbook*. Mill Valley, CA: University Science, 1989.
- [3] R. Nicole, "Title of paper with only first word capitalized," *J. Name Stand. Abbrev.*, in press.
- [4] K. Elissa, "Title of paper if known," unpublished.
- [5] D.P. Kothari, J.S. Dhillon (2012), Power system optimization, 2nd edition, PHI Learning Private Limited, 135-248.
- [6] Tapan Prakash, V. P. Singh, Sugandh P. Singh, S. R. Mohanty, "Economic load dispatch problem: quasi-oppositional self-learning TLBO algorithm," in *Energy Systems* pp.1-24, Jun 2017.
- [7] E. Ali, Optimization of power system stabilizers using BAT search algorithm, *International Journal of Electrical Power & Energy Systems* 61 (0) (2014) 683 – 690.
- [8] Selim Yilmaz, E. U. Kucuksele, A New Modification Approach on Bat Algorithm for Solving Optimization Problems, *Applied Soft Computing* 28 (2015) 259275 .
- [9] T.C. Bora, L.S. Coelho, L. Levensztajn. Bat-Inspired Optimization Approach for the Brushless DC Wheel Motor Problem. *IEEE Transactions*. 2012, 48(2): 947-950.
- [10] K.P. Wong, C.C. Fung, Simulated annealing based economic dispatch algorithm, *Proc. Inst. Elect. Eng. C* 140 (1993) 509–515.
- [11] Sinha, N., Chakrabarti, R., Chattopadhyay, P.K.: Evolutionary programming techniques for economic load dispatch', *IEEE Trans. Evol. Comput.*, 2003, 7, (1), pp. 83–94.
- [12] CH.SRINIVAS, Enhancement of Optimal Scheduling & Fuel Cost Minimization Using Flexible Genetic Algorithm, *IJCA*, Vol. 116, 2015.
- [13] Yang, X.S., . "A New Metaheuristic Bat-Inspired Algorithm", *Nature Inspired Cooperative Strategies for Optimization (NISCO 2010): Studies in Computational Intelligence*, Vol. 284, 2010, pp. 65-74.
- [14] Fister I et al., "Bat algorithm: Recent advances", *IEEE 15th Int. Symposium on Computational Intelligence and Informatics*, 2014, pp.163-167.
- [15] Ramanathan R., "Fast Economic Dispatch Based on the Penalty Factors from Newton's Method", *IEEE Transactions on Power Apparatus and Systems*, Vol. PAS-I04, No. 7, 1985, pp. 1624-1629.
- [16] Gherbi Y.A, Bouzeboudja. H, Lakdja. F., "Economic Dispatch Problem using Bat Algorithm", *Issue 24*, *Leonardo Journal of Sciences*, 2014, pp. 75-84.
- [17] Xian-Bing Meng et al, "A novel bat algorithm with habitat selection and Doppler effect in echoes for optimization", *Expert Systems with Applications* (42), 2015, pp. 6350-6364.

- [18] Biswal S. et al. "Optimal power dispatch using bat algorithm", Int. Conf. on ICEETS, 2013, pp.1018-1023.
- [19] Gaing ZL., "Particle Swarm optimization for solving economic dispatch considering the generator constraints", IEEE Trans. on Power Systems, Vo1.18, No.3, 2003, pp.1187-1195.
- [20] Kumar, Isukapalli Kranthi ; Krishna, M, "Optimal Solution to Economic Load Dispatch Using Bat Algorithm ", 6th International Conference on Advanced Computing and Communication Systems (ICACCS), 2020.
- [21] Al-Betar, Mohammed Azmi ; Awadallah, Mohammed A., "Island bat algorithm for optimization ", Academic Journal Expert Systems with Applications, Vol. 107, pp 126–145. Oct, 2018.
- [22] Gautham, S., Rajamohan, J, "Economic Load Dispatch using Novel Bat Algorithm " IEEE 1st International Conference on Power Electronics, Intelligent Control and Energy Systems (ICPEICES), 2016.
- [23] Y. A. Gherbi, H. Bouzeboudja and F. Lakdja, "Economic Dispatch Problem using Bat Algorithm ", Leonardo Journal of Sciences, no. 24, pp. 75–84, 2014.
- [24] Jose, J. T., "Economic load dispatch including wind power using Bat Algorithm ", International Conference on Advances in Electrical Engineering (ICAEE), 2014.
- [25] K. P. Wong and J. Yuryevich, "Evolutionary programming based algorithm for environmentally-constrained economic dispatch," IEEE Trans. Power System.
- [26] MATLAB Documentation. Optimization Toolbox Overview. MathWorks.